

**IEC****IECEE**

®

TM

Ref. Certif. No.

CN55967-M3/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Thermal Overload Relay

Name and address of the applicant

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.  
No.1, CHINT Road, CHINT Industrial Zone, North Baixiang  
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

*Note: When more than one factory, please report on page 2*Zhejiang CHINT Electrics Co., Ltd.  
No.2 Changjiang Road, CHINT Intelligent Electric Appliance  
Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang  
Province, P.R.China

Ratings and principal characteristics

Uimp: 8kV;Ui: 690V;Ue: 660V/690V;Ie: 23-32A,30-38A;  
3P;Trip class:10A;IP20(Front Side);Auxiliary contact  
(body) :1NO1NC;Ith:5A; AC-15: Ue/Ie:  
AC380V/400V/1.5A;DC-13: Ue/Ie: DC220V/0.2A

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

NXR-38, NXRF-38, NXR-38XM, NXRF-38XM;

Additional information (if necessary may also be  
reported on page 2)The latest CB certificate No. is CN55967-M2/A1, dated  
2023-12-12. The M3 certificate has been issued to change  
parameters.A sample of the product was tested and found  
to be in conformity withIEC 60947-4-1:2018;IEC 60947-1:2007;IEC  
60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which  
forms part of this Certificate

00901-CB2021CQC-098295-A1/M3

**CHINA QUALITY CERTIFICATION CENTRE CO., LTD.**Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: May.20,2024

Signature:

Xie ZhaoXu