

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## **CB TEST CERTIFICATE**

Product Automatic transfer switching equipment

Name and address of the applicant Zhejiang Chint Electrics Co., Ltd

No. 1, Chint Road, Chint industrial Zone, North Baixiang, Yueqing, Zhejiang

China

Name and address of the manufacturer Zhejiang Chint Electrics Co., Ltd

No. 1, Chint Road, Chint industrial Zone, North Baixiang, Yueqing, Zhejiang

China

Name and address of the factory Additional information on page 2

Note: When more than one factory, please report on page 2 Zhejiang Chint Electrics Co., Ltd

No. 1318, Binhai No. 2 Avenue, Economic and Techinical Development Zone, Wenzhou, Zhejiang

China

Ratings and principal characteristics 3P and 3P+N

Ue: 400 Vac, le: 10, 16, 20, 25, 32, 40, 50, 63 A, 50 / 60 Hz

Class CB, AC-33B, Ui: 500 V, Uimp: 4 kV lcm: 9.18 kA (NXZB-63S), 17 kA (NXZB-63H) lcn: 6 kA (NXZB-63S), 10 kA (NXZB-63H)

See annex for further ratings

Trademark (if any) CHINT

Customer's Testing Facility (CTF) Stage used

Model / Type Ref. NXZB-63S, NXZB-63H

Additional information (if necessary may also be

reported on page 2)

Additional information on page 2

A sample of the product was tested and found

to be in conformity with

IEC 60947-6-1:2005, IEC 60947-6-1:2005/AMD1:2013

As shown in the Test Report Ref. No. which

forms part of this Certificate

3311247.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V. Meander 1051, NL-6825 MJ Arnhem, Netherlands



Date: 2017-12-18

Signature: F.S.Strikwerda



Rating:

Class of equipment Utilization category Number of poles

: 400 Vac Rated voltage (Ue) Rated insulation voltage (Ui) 4 kV

Rated impulse withstand voltage

(Uimp)

Rated operational current (le)

Rated frequency

Safety distance

**EMC** environment

Control circuits Rated frequency Rated control circuit voltage (Uc)

Rated control supply voltage (Us) Transfer control devices

Monitored supply deviation

Voltage deviation

Opening time delay Closing time delay

Contact transfer time

Off time

Operating transfer time

Return transfer time

: CB

: AC-33B : 3P, 3P+N

500 Vac

:

10, 16, 20, 25, 32, 40, 50, 63 A

50 / 60 Hz

Front / Back: 0 mm,

Left / Right: 35 mm, Up / Down: 35 mm

Α

As below 50 / 60 Hz

: 230 V : 230 V

: Controller A and Controller C : Under-voltage: 75% Ue

: ±5% Ue

: 0 s - 30 s (adjustable)

: 0 s (fixed)

:  $0.5 \times (1 \pm 50\%)$  s

 $(0.5 \times (1 \pm 50\%) + closing time delay) s$ 

:  $1.4 \times (1 \pm 10\%)$  s

:  $(1.4 + \text{time delay}) \times (1 \pm 10\%) \text{ s}$ Total operating time :  $(1.4 + \text{time delay}) \times (1 \pm 10\%) \text{ s}$ 

Rating - type NXZB-63S

Rated short-circuit making capacity

(Icm)

Rated short-circuit breaking capacity

(Icn)

: 9.18 kA

6 kA

Rating - type NXZB-63H

Rated short-circuit making capacity : 17 kA

(Icm)

Rated short-circuit breaking capacity : 10 kA

(Icn)

## Additional information

Nomenclature breakdown:

NXZB - 63 S / 4 C b c d e

a - code denoting the series name: NXZB

b - code denoting the rated current of frame: 63 A

c - code denoting the short-circuit breaking capacity: S (6 kA), H (10 kA)

d - code denoting the number of pole: 3P, 4P (3P+N)

e - code denoting the controller: controller A, controller C